

Asbestos Analysis Report

Tuesday, 2nd August, 2016

Supplier: Magnesium Oxide Board Corporation Asia

Suppliers Address: South West of Interchange of Yihe East Road and Kunming Road, National Economic and Technological Development Zones of Linyi City Shandong

Sample Description: ResCom External Wall Board (Green) and ResCom Structural Flooring (Dark Brown)

Date Tested: 1st August 2016 (Tested through COHLAB Pty Ltd – NATA Accreditation 19449)

Test Method: AS 4964-2004 "Method for the qualitative identification of asbestos in bulk samples".

The samples were collected in the presence of the Australian Border Force. Samples were subsequently analysed at COHLABS a NATA accredited laboratory in Brisbane. The laboratory results are summarized in the following table:

Sample Number	Sample Identification	Result
102373	ResCom External Wall Board (Green) ResCom HMR (35mm R/E) 10mm x 1200mm x 2700mm	No asbestos detected
102374	ResCom Structural Flooring (Dark Brown) ResCom SF (ShipLap Joint) 18mm x 920mm x 2250mm	No asbestos detected

Results confirm that no asbestos materials were present in the board samples analysed. It is CETEC's opinion that the boards can be released. Refer to Appendix A for Laboratory results.



Brooke Maetam
BEnvMgt (Hons)
Graduate Consultant



Josiah Padget
MOHS& EnvMgt BAppSc
MEAINZ
QLD Client Services Coordinator



Dr. Vyt Garnys
PhD, BSc (Hons), AusIMM, ARACI,
ISIAQ, ACA, AIRAH, FMA
Managing Director & Principal
Consultant

Appendix A: Laboratory Analysis Certificate



PO Box 5324
West End QLD 4101
Tel. 07 3015 7555

CERTIFICATE OF ANALYSIS
Asbestos Identification

Certificate No: 16-2361

Client:	CETEC Pty Ltd and FORAY Laboratories Pty Ltd	Date Sampled:	1/08/2016
Client Contact:	Brooke Maetam	Date Received:	1/08/2016
Telephone:	3808 3948	Date Analysed:	1/08/2016
Email:	brisbane@cetec.com.au	Order No.:	CB160754.1
Address:	2, 14 Venessa Boulevard Springwood QLD 4127	Sampled By:	As Received
Site:	Site 1		

Test Method:

Qualitative identification of asbestos types in bulk samples at COHLABS Laboratory by polarized light microscopy, including dispersion staining techniques using COHLABS in-house method ID-1, AS 4864 (2004). The results contained within this report relate only to the sample(s) submitted for testing. COHLABS accepts no responsibility for the initial collection, packaging or transportation of samples submitted by external persons. This document may not be reproduced except in full.

Lab ID	Sample ID	Sample Details	Sample Type	Size / Weight cm/g	Asbestos Present	Fibres Identified
001	102373	Green	Fibrous Board	3 x 2	No	NAD, SMF
002	102374	Brown	Fibrous Board	2 x 2	No	NAD, SMF

Fibre Identification Legend

CHR	Chrysotile (white asbestos)	ORF	Organic Fibre
AMO	Amosite (Brown/Grey asbestos)	SMF	Synthetic Mineral Fibre
CRO	Crocidolite (Blue asbestos)	NFD	No Fibres Detected
UMF	Unknown Mineral Fibre	NAD	No Asbestos Detected

Approved Identifier

Name: Michael Shepherd



Approved Signatory

Name: Michael Shepherd




NATA Accreditation number: 19499
Accredited for compliance with ISO/IEC: 17025. The results of tests, calibrations, and/or measurements included in this document are traceable to Australian/national standards.

ABN: 62 166 540 094

Page 1 of 1